



- NOTE:
1. EDGES TO BE SAWED WITH A CONCRETE SAW TO A NEAT SQUARED EDGE BROOMED CLEAN OF DUST BEFORE TACK COAT IS APPLIED.
 2. EDGES AND OVERLAY AREAS AND OVERLAY AREAS TO BE TACKED WITH RC OR AE-1 SPECIAL TACK.
 3. 6" LIFTS OR SUITABLE SOIL OR ABC AT OPTIMUM MOISTURE COMPACTED 95% STANDARD PROCTOR, ALL WET OR UNSUITABLE MATERIAL TO BE REMOVED FROM SITE PRIOR TO BACKFILL.
 4. N.C.D.O.T. APPROVED PATCH DETAIL

REVISIONS	
DATE	DESCRIPTION



CITY OF ASHEVILLE, N.C.
ENGINEERING DEPARTMENT

PAVEMENT REMOVAL AND REPLACEMENT

STD. No.

5.01